



CPRI

HEAT RUN TEST LABORATORY
DIAGNOSTIC, CABLES & CAPACITORS DIVISION
CENTRAL POWER RESEARCH INSTITUTE
P.B.NO.8066, SADASHIVANAGAR SUB P.O
PROF.SIR.C.V.RAMAN ROAD, BANGALORE - 560 080, INDIA
Phone: + 91 (0) 80-2360 4435 Fax: 080 - 2360 4435



NABL Accredited
Laboratory
Cert. No. T- 0010

Sheet 1 of 4

TEST REPORT

Test Report Number : DCCD - 11829 **Dated:** 15.12.2010

Name & Address of the Customer : M/s. Switchgear & Control Automations,
No. 37, 5th Cross, Doddamma Industrial layout,
Hulimavu, Bannerghatta Road,
Bangalore- 560 076.
Ref: Letter no SCA/HRT/02 Dated: 15.10.2010

Name & Address of the Manufacturer : M/s. Switchgear & Control Automations,
No. 37, 5th Cross, Doddamma Industrial layout,
Hulimavu, Bannerghatta Road,
Bangalore- 560 076.

Particulars of sample tested : 3000Amps, PCC LT Panel
Condition of the Sample on Receipt : New
Type : Indoor
Designation : PCC LT Panel
Serial Number : Nil
Number of samples tested : One
Date(s) of Test(s) : 13.12.2010
CPRI sample code no : SC10S1992
Particulars of tests conducted : Temperature rise test at 3000Amps.
Test in accordance with standard/specification : IS 8623 Part-1-1993/ IEC 60439 Part-1-1985.
Sampling plan : Nil
Customers requirement : Temperature rise test at 3000 Amps.
Deviations if any : Nil

Name of the witnessing persons
Customers representatives : Mr. Murthy Pillai
Other than Customers representatives : Nil
Test subcontracted with address of the laboratory : NA

Documents constituting this report (in words)
Number of Sheets : Four
Number of oscillograms : Nil
Number of graphs : Nil
Number of photos : Nil
Number of Test Circuit Diagrams : Nil
Number of Drawings : Two: 1) SCA/HRT/10-11, SHT.No 1 OF 2
2) SCA/HRT/10-11, SHT.No 2 OF 2


(G.P.VITTAL)
Test Engineer




(A.SUDHINDRA)
Additional Director

AUTHORISED SIGNATORIES